



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

NOTICE OF ACCEPTANCE (NOA)

**MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION**

11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786) 315-2590 F (786) 315-2599

www.miamidade.gov/economy

Siplast, Inc.
1111 Highway 67 South
Arkadelphia, AR 71923

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami-Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (in Miami-Dade County) and/or the AHJ (in areas other than Miami-Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Siplast Liquid Applied Roofing Systems over Recover Decks

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA No.15-0714.14 and consists of pages 1 through 4.

The submitted documentation was reviewed by Gaspar J Rodriguez.



NOA No.: 16-0322.15
Expiration Date: 12/16/20
Approval Date: 06/23/16
Page 1 of 4

ROOFING SYSTEM APPROVAL

Category: Roofing
Sub-Category: Liquid Applied Roof Systems
Material: PMMA
Deck Type: Recover
Maximum Design Pressure: See Specific Deck Type

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Parapro Liquid Applied Membrane	20–kg Drums	Proprietary	A liquid applied reinforced PMMA membrane system.
Parapro Roof Membrane Resin	20–kg Drums	Proprietary	Multi-component PMMA resin.
Pro Fleece	12”x 16.5’ roll 12”x 82’ roll 25”x 164’ roll 41”x 164’ roll	Proprietary	Non-woven, needle punched, polyester fabric reinforcement.
Pro Primer R Resin	5–kg & 10–kg Drums	Proprietary	PMMA primer component for use over BUR, modified bitumen or other soft substrates.
Pro Primer W Resin	5–kg & 10–kg Drums	Proprietary	PMMA primer component for use over wood, concrete or other hard substrates.
Pro Primer T Resin	5–kg & 10–kg Drums	Proprietary	PMMA primer component for use over wood, concrete or other hard substrates.
Pro Catalyst Powder	Box of 10 3.2oz bags	Proprietary	Reactive agent for use during priming and membrane application.
Pro Color Finish Resin	5–kg & 10–kg Drums	Proprietary	Color pigmented, multi component, flexible PMMA.

APPROVED INSULATIONS:

TABLE 2

<u>Product</u>	<u>Description</u>	<u>Manufacturer (With Current NOA)</u>
N/A	N/A	N/A

APPROVED FASTENERS:

TABLE 3

<u>Fastener Number</u>	<u>Product</u>	<u>Description</u>	<u>Dimension</u>	<u>Manufacturer (With Current NOA)</u>
1.	N/A	N/A	N/A	N/A



EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
Factory Mutual	3029275	FM 4470	03/24/08
	3027962	FM 4470	10/03/06
	3042750	FM 4470	01/20/12
Trinity ERD	C8500SC.11.07	TAS 117-B / ASTM D6862	11/30/07
	C8500SC.11.07-R1	TAS 117-B / ASTM D6862	08/07/09
	S9000.03.09-R1	Physical Properties	05/06/09
		G155/D638	
		ASTM D1929/D2843/D635	
		TAS 114-D/ TAS 114-J	
	S31630.05.10	ASTM D6163	05/11/10
	S31450.03.10	ASTM E154 / E96	03/22/10
	SPL-SC6940.06.15	PMMA Physical Properties	06/18/15
Momentum Technologies, Inc.	TX31G6A	Physical Properties	08/19/09
PRI Construction Materials Technologies	SRI-087-02-01	Physical Properties	02/26/16

APPROVED ASSEMBLIES:

Membrane Type: Liquid Applied Membrane

Deck Type 7: Recover, Non-Insulated

Deck Description: Concrete

System Type F: Siplast system applied directly to existing roof.

All General and System Limitations apply.

Primer: (Optional) Apply Pro Primer R Resin to the properly prepared existing asphaltic BUR roof covering system at a minimum rate of 0.082 lb/ft².

Membrane: Base coat of Parapro Roof Membrane Resin roller applied at a minimum rate of 0.42 lb/ft² onto the primer or the properly prepared existing asphaltic BUR roof covering system; followed by one ply of Pro Fleece laid in the wet base coat; followed by a top coat of Parapro Roof Membrane Resin roller applied at a minimum rate of 0.27 lb/ft² onto the embedded Pro Fleece.

Maximum Design Pressure: -262.5 psf (See General Limitation #9)



RECOVER SYSTEM LIMITATIONS:

1. All System Limitations and General Limitations shall apply. See specific deck type Notice of Acceptance for deck type System Limitations.

GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20–40 lbs./100 ft², or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each sidelap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./100 ft². **Note: Spot attached systems shall be limited to a maximum design pressure of –45 psf.**
5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida Registered Engineer, Registered Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. Calculations prepared, signed and sealed by a Florida Registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform with Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

END OF THIS ACCEPTANCE

